



NOTES:

1. MINIMUM PAVEMENT SECTION DEPTHS SHALL BE AS SHOWN IN STANDARD DETAIL S4 FOR LOCAL ACCESS STREETS.
2. INSTALL A TYPE III BARRICADE AT END OF CUL-DE-SAC AS DIRECTED BY THE CITY ENGINEER, SEE DETAIL S13
3. MINIMUM SIDEWALK WIDTH IS 5 FEET, SEE DETAIL S8
4. VERTICAL CURB AND GUTTER PER DETAIL S10
5. ROADSIDE RESTORATION AND GRADING SHALL NOT BE STEEPER THAN 2H:1V.

Approved:  June 17, 2005
 City Engineer Date
STREET STANDARD DETAIL



Dwg No: **S5**
CUL-DE-SAC