



NOTES:

1. BLOW-OFF HYDRANTS SHALL BE NON-FREEZING, SELF-DRAINING TYPE.
2. SET UNDERGROUND IN CITY APPROVED METER BOX, THESE HYDRANTS WILL BE FURNISHED WITH A 2" FIP INLET, AND BE SERVICEABLE FROM ABOVE GRADE WITH NO DIGGING.
3. THE OUTLET SHALL ALSO BE BRONZE AND BE 2-1/2" NST.
4. HYDRANTS SHALL BE LOCKABLE TO PREVENT UNAUTHORIZED USE.
5. LOCATE WIRE SHALL BE 10 GAUGE WIRE FROM 2" GV TO METER BOX W/ 6" MIN. EXPOSED WITHIN BOX.

Approved:

June 17, 2005

City Engineer

Date

WATER STANDARD DETAIL



Dwg No:

W13

**2" BLOW-OFF
ASSEMBLY**