



**NOTES:**

1. GATE VALVE: AWWA RESILIENT SEAL, FIPT x FIPT WITH 2" OPERATING NUT.
2. ALL PIPING BETWEEN DOUBLE STRAP SADDLE AND INLET SIDE OF 2" GV SHALL BE BRASS.
3. TAP MAIN AT SYSTEM HIGH POINT. LOCATION TO BE APPROVED BY THE CITY.

Approved:  June 17, 2005  
 City Engineer Date

**WATER STANDARD DETAIL**



Dwg No:

**W14**

**AIR AND VACUUM  
RELEASE ASSEMBLY**